



# Technical Appendix 2.2: Carbon Balance Assessment

## Dalfad Wind Farm

### Brockwell Energy Limited

Prepared by:

**SLR Consulting Limited**

The Tun, 4 Jackson's Entry, Edinburgh, EH8 8PJ

SLR Project No.: 413.057968.00001

9 September 2026

Revision: 1.0

## Revision Record

| Revision | Date             | Prepared By | Checked By | Authorised By |
|----------|------------------|-------------|------------|---------------|
| 01       | 9 September 2026 | A.Dickson   | D.Nisbet   | D.Nisbet      |

## Basis of Report

This document has been prepared by SLR Consulting Limited (SLR) with reasonable skill, care and diligence, and taking account of the timescales and resources devoted to it by agreement with Brockwell Energy Limited (the Applicant) as part or all of the services it has been appointed by the Applicant to carry out. It is subject to the terms and conditions of that appointment.

SLR shall not be liable for the use of or reliance on any information, advice, recommendations and opinions in this document for any purpose by any person other than the Applicant. Reliance may be granted to a third party only in the event that SLR and the third party have executed a reliance agreement or collateral warranty.

Information reported herein may be based on the interpretation of public domain data collected by SLR, and/or information supplied by the Applicant and/or its other advisors and associates. These data have been accepted in good faith as being accurate and valid.

The copyright and intellectual property in all drawings, reports, specifications, bills of quantities, calculations and other information set out in this report remain vested in SLR unless the terms of appointment state otherwise.

This document may contain information of a specialised and/or highly technical nature and the Applicant is advised to seek clarification on any elements which may be unclear to it.

Information, advice, recommendations and opinions in this document should only be relied upon in the context of the whole document and any documents referenced explicitly herein and should then only be used within the context of the appointment.



## Table of Contents

|            |                                      |          |
|------------|--------------------------------------|----------|
| <b>1.0</b> | <b>Introduction .....</b>            | <b>2</b> |
| <b>2.0</b> | <b>Input Parameters .....</b>        | <b>4</b> |
| <b>3.0</b> | <b>Carbon Calculator Output.....</b> | <b>8</b> |



## Acronyms and Abbreviations

|                 |                                             |
|-----------------|---------------------------------------------|
| oBEMP           | Biodiversity Enhancement Management Plan    |
| CO <sub>2</sub> | Carbon Dioxide                              |
| DESNZ           | Department for Energy Security and Net Zero |
| DUKES           | Digest of UK Energy Statistics              |
| ECU             | Energy Consents Unit                        |
| GHG             | Greenhouse Gas                              |
| ha              | hectare                                     |
| Lidar           | Light Detection and Ranging                 |
| MW              | Megawatt                                    |
| SEPA            | Scottish Environment Protection Agency      |
| UKERC           | UK Energy Research Centre                   |



## 1.0 Introduction

Increasing atmospheric concentrations of greenhouse gases (GHGs), including carbon dioxide (CO<sub>2</sub>), also referred to as carbon emissions, are resulting in climate change. A major contributor to this increase in GHG emissions is the burning of fossil fuels. With concern growing over climate change, reducing its cause is of utmost importance. The replacement of traditional fossil fuel power generation with renewable energy sources provides high potential for the reduction of GHG emissions. This is reflected in UK and Scottish Governments' climate change and renewable energy policy and commitments.

Whilst the Proposed Development will reduce carbon emissions by replacing the need to burn fossil fuels for power, no form of electricity generation is completely carbon free; for onshore wind farms, there will be emissions resulting from component manufacturing, transportation and installation processes associated with the Proposed Development.

In addition to the lifecycle emissions from the development equipment and infrastructure, where a development is located on carbon rich soils such as peat or within forestry, there are potential emissions resulting from direct action of excavating peat for construction and also the indirect changes to hydrology that can result in losses of soil carbon, as well as forestry felling. The footprint of a development's infrastructure will also decrease the area covered by carbon-fixing vegetation.

Conversely, restoration activities undertaken post-construction or post-decommissioning could have a beneficial effect on carbon uptake through the restoration of modified bog habitat. Carbon losses and gains during the construction and lifetime of a wind farm, and the long-term impacts on the peatlands on which they are sited, need to be evaluated to understand the consequences of permitting such developments.

A technical review of energy displacement by the UK Energy Research Centre (UKERC) considered over two hundred studies and papers from around the world for the UK Government and concluded that "it is unambiguously the case that wind energy can displace fossil fuel-based generation, reducing both fuel use and carbon dioxide emissions" (UKERC, 2006). Whilst the wind turbines will reduce carbon emissions by replacing the need to burn fossil fuels for power, there is the potential for carbon fixers and sinks to be lost through the clearing of vegetation and materials for construction. There must therefore be a sufficient balance between the carbon reduced and that which is produced and lost through associated processes.

## Methodology

All applications that are over 50 Megawatt (MW) are dealt with through the Scottish Government's Energy Consents Unit (ECU) in accordance with Section 36 of the Electricity Act 1989. In accordance with the Electricity Works (Environmental Impact Assessment) (Scotland) Regulations 2017, the EIA Report is required to include a description of the likely significant effects of the Proposed Development on climate, including the nature and magnitude of GHG emissions.

To support this assessment a carbon balance assessment has been undertaken using the Scottish Government's online 'Carbon Calculator' tool, that can be used to calculate the greenhouse gas emissions and carbon payback times for wind farm developments on Scottish peatlands. This online tool is supported by two documents published by the Scottish Government and Scottish Renewables, and Scottish Environment Protection Agency (SEPA) to aid in calculating the potential carbon losses and savings.

At the time of submission, the online tool is not accessible, and therefore the assessment has been undertaken using the Carbon Assessment Tool spreadsheet (v2.15.6), issued by SEPA.



The Carbon Calculator compares an estimate of the carbon emissions from the construction, operation, and decommissioning of the Proposed Development to those emissions estimated from other electricity generation sources. Input parameters are based on the proposed site design, infrastructure dimensions, results from peat depth surveys, and other information gained from site survey work, desk study and, where applicable, assumptions relating to groundwater, drainage, and habitat regeneration. As no infrastructure has yet been constructed for the Proposed Development, the assumptions relating to infrastructure have been based on the design envelope for the Proposed Development or from standard, default representative information.



## 2.0 Input Parameters

The carbon calculator submitted allows a range of data to be input to utilise expected, minimum and maximum values, where relevant and applicable. If several parameters are varied together, however, this can have the effect of ‘cancelling out’ a single parameter change. For this reason, the approach for this assessment, has been to include ‘maximum values’ as those values which would result in longest (maximum) payback period; and ‘minimum values’ as those values which would result in the shortest (minimum) payback period. The expected value is based on the most realistic option for the site.

Information relating to the Proposed Development (including consideration of design, operation, and construction) has been collated, and includes details of the proposed infrastructure, local ecology, and restoration proposals associated with the Proposed Development. This collated information has been entered into the Carbon Assessment Tool spreadsheet and is outlined below.

### Wind Farm Characteristics

The Proposed Development will comprise up to 14 wind turbines. Nine turbines will be up to 200 m tip height with an expected power rating capacity of 6.4 MW, with the remaining five turbines at 149.9 m tip height with an expected power rating capacity of 4.5 MW. Therefore, the average power rating capacity is expected to be 5.7 MW. The operational life of the Proposed Development is expected to be 40 years.

### Capacity Factor

The expected capacity factor is 39.3 %, based on site-specific Light Detection and Ranging (Lidar) measurements and yield assessment.

### Back Up

The Carbon Calculator indicates that if over 20 % of national electricity is generated by wind energy, the extra capacity required for backup is 5 % of the rated capacity of the wind plant. The values for ‘fraction of output to backup’ are therefore input as expected 5 % and maximum 5 % to represent full requirement for backup, and a minimum of 0 % to represent no backup required (Nayak et al., 2008). SEPA indicates that for this parameter, the electricity generation capacity of Scotland, rather than the UK, should be considered. In 2022, Scotland generated about 66 % of gross electricity consumption via onshore wind (Scottish Renewables Statistics, 2023). Where the balancing capacity is obtained from fossil fuel generating stations, emissions will increase by 10 % due to reduced thermal efficiency of the reserve generation stations (Dale et al., 2004). This value is fixed in the Carbon Calculator.

### CO<sub>2</sub> Emissions from Turbine Life (tCO<sub>2</sub>/MW)

CO<sub>2</sub> emissions during the life of a wind turbine include emissions that occur during the manufacturing, transportation, erection, operation, dismantling and removal of the structures. As there is no direct Life Cycle Assessment for the Proposed Development available at this point in time, the inbuilt Carbon Calculator option which allows for emissions to be calculated according to wind turbine capacity has been selected.

## Characteristics of Peatland Before Wind Farm Development

### Type of Peatland

The most appropriate habitat description available on the Carbon Calculator is Acid Bog, refer to **Chapter 6: Ecology**.



## **Average Annual Air Temperature at Site**

The average annual air temperature of 8.04°C is based on average annual temperature data from the Met Office UK climate averages (Met Office, 2025). The nearest climate station which provides this information is located at Saughall, Darvel, approximately 20 km south of the site.

## **Average Peat Depth at Site**

The average peat depth of 0.35 m was calculated based on peat probe data from within the site boundary of the Proposed Development.

The assessment is based on a series of average soil depths taken from peat surveys undertaken at the site. Probe locations on mineral and peaty soils (<0.5 m) are included within the averages.

## **Carbon Content of Dry Peat**

Site specific values are not available, so the standard values from the 'Windfarm Carbon Calculator Web Tool, User Guidance' have been used. The carbon content ranges from 48 % to 57 % with an expected value of 52 % used. This reflects a range of values typical of the carbon content anticipated from Scottish Peatlands (Birnie et al 1991 and Lindsay 2010).

## **Average Extent of Drainage around Drainage Features at Site**

Site specific values are not available, so the standard values from the 'Windfarm Carbon Calculator Web Tool, User Guidance' have been used. The expected value is 10 m, with a minimum of 5 m and maximum of 50 m.

## **Average Water Table Depth at Site**

Site specific values are not available, so the values for 'intact peat' from 'Windfarm Carbon Calculator Web Tool, User Guidance' have been used as a worst-case scenario. The expected value is 0.3 m, with a minimum 0.1 m, and a maximum 0.5 m.

## **Dry Soil Bulk Density**

A representative site-specific value for this parameter, Scottish generic values for peat from 'Windfarm Carbon Calculator Web Tool, User Guidance' have been used. The expected value is 0.132 g/cm<sup>3</sup>, with a minimum of 0.072 g/cm<sup>3</sup> and a maximum of 0.293 g/cm<sup>3</sup>.

## **Characteristics of Bog Plants**

### **Time Required for Regeneration of Bog Plants After Restoration**

This can vary widely depending on the location of the site and the target bog plants for restoration, and whether the ground was previously afforested or open moorland. The speed of regeneration will also depend on species present and their colonising ability and traits, as well as the methods of restoration and maintenance of hydrology. Typical bog plants may take longer to establish where suitable conditions exist. The values stated take this into account considering available literature and anecdotal observations of wind farms in Scotland.

As such, five years has been stated as a reasonable precautionary estimate for the regeneration time needed for most bog species, with a minimum of three years and a longer establishment time of 15 years.

## **Carbon Accumulation**

The Carbon Calculator Guidance (Technical Note, Version 2.15.0, Scottish Government) suggests a mid-range value of 0.25 tC ha<sup>-1</sup> yr<sup>-1</sup> and a range of 0.12 to 0.31 t C ha<sup>-1</sup>yr<sup>-1</sup>.



## Forestry Plantation Characteristics

### Area of Forestry Plantation to be Felled (ha)

There is no net loss of forestry plantation from felling. Any crops that are cleared will be replanted back on the site or on a compensatory planting site so that the overall area of forestry is maintained.

### Average Rate of Carbon Sequestration in Timber

The average rate of carbon sequestration in timber to be felled on-site has been calculated as 3.6 tC ha<sup>-1</sup> yr<sup>-1</sup> (Cannell, 1999).

## Counterfactual Emission Factors

The counterfactual emission factors for three methods of energy generation are fixed in the carbon calculator. Values for both coal-fired and fossil fuel-mix emission factors are updated from Digest of UK Energy Statistics (DUKES) data for the UK which is published annually. The source for the grid-mix emission factor is the list of emission factors used to report on greenhouse gas emissions by UK organisations published by the Department for Energy Security and Net Zero (DESNZ).

## Borrow Pits

There are no proposed borrow pits as part of the Proposed Development, therefore this section has been omitted from this assessment.

## Foundation and Hardstand Areas

The wind turbine foundations for the Proposed Development are expected to measure approximately 30 m in diameter, with hardstands expected to measure approximately 100 m x 25 m.

The average peat depth in the turbine foundation areas is 0.4 m, and the average peat depth in the hardstand areas is 0.3 m. Conservatively, organic and mineral soils (<0.5 m) have also been used in the calculation of averages.

## Access Tracks

There is 14,218 m of existing track to be upgraded within the Proposed Development site. The total length of new access tracks proposed is approximately 11,793 m. Small changes to the access track layout may occur post consent (e.g., as a result of micro-siting) leading to minor variations to the overall track length.

The average peat depth on the route of the proposed cut access track is 0.28 m. Conservatively, organic soils (<0.5 m) have also been used in the calculation of averages.

## Cable Trenches

The wind farm array cables on-site will be laid in trenches, laid on a sand bed and backfilled using suitably graded material, and will mainly be located adjacent to the access tracks within the Proposed Development.

## Additional Peat Excavated

There is no additional peat predicted to be excavated across the remainder of the proposed infrastructure. Further information can be found in **Technical Appendix 8.2 Outline Peat Management Plan**.



## Peat Landslide Hazard

The peat landslide hazard is a fixed value automatically defined by the Carbon Calculator and is shown to be 'negligible'.

## Restoration of Site after Decommissioning

The **Technical Appendix 6.6**, outline Biodiversity Enhancement Management Plan (oBEMP) outlines the proposed habitat and conservation management measures in relation to the Proposed Development. Due to the small, fragmented, and limited nature of the peatland on-site, there is limited restoration options present, therefore no restoration is planned at present.



## 3.0 Carbon Calculator Output

The output from the Carbon Calculator indicates the expected total carbon dioxide loss for the Proposed Development (from manufacture of turbines, construction, decommissioning, and carbon sink losses) is 135,784 tonnes of carbon dioxide (tCO<sub>2</sub> eq). Input and output parameters are detailed in Annex A.

Scottish Government guidance on wind farm carbon savings (Scottish Government, 2022), states: “*carbon emission savings from wind farms should be calculated using the fossil fuel sourced grid mix as the counterfactual, rather than the grid mix.*” Taking account of the expected total CO<sub>2</sub> loss from the Carbon Calculator result, the Proposed Development would be expected to result in a saving of approximately 123,603 tonnes of carbon dioxide (tCO<sub>2</sub>) per annum, meaning a total of over 4.9 million tonnes over the 40-year operational lifetime of the Proposed Development, through displacement of carbon-emitting generation.

The carbon payback time of the Proposed Development is between 0.3 and 1.9 years, with an expected payback period of 1.1 years (approximately 13 months). This is the period of time for which a wind farm needs to be in operation before it has, by displacing generation from fossil-fuelled power stations, avoided as much carbon dioxide as was released in its lifecycle.

As recommended in current guidance estimated savings are for replacement of fossil fuel electricity generation but, while this could be the case in the short term, it is not the most probable scenario in the longer-term. The grid-mix of electricity generation represents the overall carbon emissions from the grid per unit of electricity and includes nuclear and renewables as well as fossil fuels. Based on the grid-mix results, the Proposed Development is expected to result in a saving of approximately 48,834 tCO<sub>2</sub> per annum with an expected carbon payback time of 2.8 years.





Making Sustainability Happen